

Kennebunkport Fire Department Water Supply Information

December 10, 2021

GPM Approximate length of hose lay to entire road or addresses listed is shown

1500	1500 +
1000	1000-1500
750	500-999
500	500 or less
DH	Dry Hydrants / Approximate flow and estimated duration shown /see next listed info for each

ROAD	GPM	WATER SUPPLY/DISTANCE
ABBAY ROAD	DH	DRY HYDRANT AT 16 WINTER HARBOR ROAD MAX LAY 1400' 250-500 GPM, 250 GPM 2 Hours
ABENAKI WAY	DH	DRY HYDRANT ON 40,000 GALLON CISTERN AT 30 ABENAKI WAY 1000' LAY 250-500 GPM, 250 GPM 2 Hours
ACACIA ROAD	1000	HYDRANT AT 11 MAGNOLIA DRIVE MAX LAY 800'
AFFETON LANE	1000	HYDRANT IS AT 98 WILDES DISTRICT ROAD
AGAMENTICUS AVE.	1000	LAY HYDRANT IS AT AGAMENTICUS AND SUMAC 200' IN FROM FISHERS LANE. MAX LAY OF 1400'
APPLE BLOSSOM LANE	DH	LAY HYDRANT AT 88 GOOSE ROCKS ROAD MAX LAY OF 1200' 250-500 GPM, 250 GPM 2 Hours
ARBOR LEDGE DRIVE	1000	HYDRANT AT WILDES DISTRICT ROAD AND MAINE STREET WITHIN 1000'
ARLINGTON AVENUE	1000	HYDRANTS 2 AND 14 ARLINGTON STREET
ARUNDEL ROAD	1500	9 ARUNDEL ROAD HYDRANT AT 54 RIVER ROAD
	1500	49 ARUNDEL ROAD HYDRANT AT 49 ARUNDEL ROAD
	1500	102 ARUNDEL ROAD HYDRANT AT 138 NORTH STREET WITHIN 1500' LAY
	1500	103-106 ARUNDEL ROAD HYDRANT AT 138 NORTH STREET WITHIN 1600'
		113 ARUNDEL ROAD DRY HYDRANT AT 145 ARUNDEL ROAD 1600' LAY
		123-127 ARUNDEL ROAD DRY HYDRANT AT 145 ARUNDEL ROAD 1100'
		130-165 ARUNDEL ROAD DRY HYDRANT AT 145 ARUNDEL ROAD 1000'
	DH	250-500 GPM, 250 GPM 2 Hours
		170-210 ARUNDEL ROAD DRY HYDRANT AT 194 ARUNDEL ROAD 1200' LAY
	DH	250-500 GPM, 250 GPM 2 Hours
		225-232 ARUNDEL ROAD DRY HYDRANT AT 5 THE LONG & WINDING ROAD, 1100' LAY
	DH	250-500 GPM, 250 GPM 2 Hours
		236-252 ARUNDEL ROAD DRY HYDRANT AT 251 ARUNDEL ROAD W/1000'
	DH	250-500 GPM, 250 GPM 2 Hours
		283 ARUNDEL ROAD DRY HYDRANT IN DRIVEWAY
	DH	250-500 GPM, 250 GPM 2 Hours
		286-340 ARUNDEL ROAD DRY HYDRANT AT 293 ARUNDEL ROAD 1000' LAY
	DH	250-500 GPM, 250 GPM 2 Hours
ATLANTIC AVENUE		NO HOUSES ON THIS STREET EITHER LISTED AS OCEAN AVE OR SUMMIT AVE
BACK HARBOR ROAD	1500	HYDRANT AT 11 MILLS ROAD MAX LAY 1200'
BAILEY COURT	1500	LOCATED AT INTERSECT OF SCHOOL STREET AND BAILEY IN A SMALL GROUP OF PINE TREES, ON THE RIGHT ENTERING.
BARTER LANE	1500	HYDRANT AT 138 NORTH STREET W/1000'
BARTLETT AVENUE	1500	5-9 BARTLETT AVE HYDRANT AT BARTLETT AND KINGS HIGHWAY W/1000'
BATH LANE	1500	HYDRANT AT MAIN AND OLD CAPE ROAD MAX LAY OF 2200'
BATSON CREEK ROAD	DH	DRY HYDRANT AT 26 BATSON CREEK ROAD 250-500 GPM, 250 GPM 2 HOURS
BEACH ROSE LANE	750	HYDRANT AT 2 FIELD POINT ROAD W/1000'

BEACHWOOD AVENUE	1500	7-20 BEACHWOOD AVE HYDRANT AT NORTH AND BEACHWOOD W/1000'
	1500	19-21 BEACHWOOD AVE HYDRANT AT NORTH & BEACHWOOD W/1500'
		31-35 BEACHWOOD AVE DRY HYDRANT AT 64 BEACHWOOD W/1440'
		45-83 BEACHWOOD AVE DRY HYDRANT AT 64 BEACHWOOD W/1000'
	DH	250-500 GPM, 250 GPM 2 Hours
		85-126 BEACHWOOD DRY HYDRANT AT 106 BEACHWOOD AVE W/1000'
	DH	250-500 GPM, 250 GPM 2 Hours
		131-133 BEACHWOOD AVE DRY HYDRANT AT 112 BEACHWOOD W/1000'
		134 BEACHWOOD AVE DRY HYDRANT AT 112 BEACHWOOD AVE W/1100'
		144 BEACHWOOD AVE DRY HYDRANT AT 112 BEACHWOOD AVE W/1600'
	158 BEACHWOOD AVE DRY HYDRANT AT 112 BEACHWOOD AVE W/2300'	
	160 BEACHWOOD AVE DRY HYDRANT AT 112 BEACHWOOD AVE W/2500'	
DH	250-500 GPM, 250 GPM 2 Hours	
	172 BEACHWOOD AVE DRY HYDRANT AT 236 BEACHWOOD AVE W/3300'	
	176 BEACHWOOD AVE DRY HYDRANT AT 236 BEACHWOOD AVE W/3000'	
	178-179 BEACHWOOD AVE DRY HYDRANT AT 236 BEACHWOOD W/2900'	
	180-184 BEACHWOOD AVE DRY HYDRANT AT 236 BEACHWOOD W/2700'	
	205-207 BEACHWOOD AVE DRY HYDRANT AT 236 BEACHWOOD AVE W/1600'	
	215-261 BEACHWOOD AVE DRY HYDRANT AT 236 BEACHWOOD AVE W/1000'	
	263-268 BEACHWOOD AVE DRY HYDRANT AT 172 MILLS ROAD W/1000'	
DH	500-750 GPM, 250 GPM 4 hours	
BEACON AVENUE		2-18 BEACON AVE DRY HYDRANT AT 178 GUINEA ROAD W/1000'
	DH	500-750 GPM, 250 GPM 4 hours
BEAVER POND ROAD	750	4-36 BEAVER POND ROAD HYDRANT AT COMMUNITY HOUSE DRIVE MAX LAY IS 2800'
	DH	DRY HYDRANT WINTER HARBOR ROAD MAX LAY 3300' 250-500 GPM, 250 GPM 2 Hours
BEECH STREET	1500	6-16 BEECH STREET HYDRANT AT PIER AND FISHERS LANE W/1000'
BELAIR AVENUE	1500	3-12 BELAIR AVE HYDRANT AT BARTLETT AND KINGS HIGHWAY W/1200'
BELLEGLADE AVENUE	1500	2-6 BELLEGLADE AVE HYDRANT AT BARTLETT AND KINGS HIGHWAY W/1000'
BELLEVUE AVENUE	1500	2-12 BELLEVUE AVE HYDRANTS AT BARTLETT AND KINGS HIGHWAY AND 252
	1500	KINGS HIGHWAY (TIDES INN) W/1000'
BELLEWOOD AVE	1500	11 BELLEWOOD AVE HYDRANTS AT BARTLETT AND KINGS HIGHWAY AND 891
	1500	KINGS HIGHWAY (TIDES INN) W/1000
BELVIDERE AVENUE	1500	3-16 BELVIDERE AVE HYDRANT AT 891 KINGS HIGHWAY (TIDES INN)
BENSON AVENUE	750	4-8 BENSON AVE HYDRANT AT 1176 KINGS HIGHWAY W/1000'
BERYLS WAY	1000	HYDRANT AT 68 MILLS ROAD 1500' TO START OF ROAD
BINNACLE HILL	1000	HYDRANT AT 34 NEW BIDDEFORD ROAD
	750	HYDRANT IN CUL-DE-SAC
BLACKBERRY HILL RD		1-20 BLACKBERRY HILL ROAD DRY HYDRANT AT BEACHWOOD AND BATSON RIVER W/1500'
	DH	250-500 GPM, 250 GPM 2 Hours
BLUEBERRY LANE		18 BLUEBERRY LANE DRY HYDRANT AT GUINEA AND COLE BENSON ROAD W/1500'
	DH	250-500 GPM, 250 GPM 2 Hours
BLUE HERON DRIVE	1500	2-10 BLUE HERON DRIVE HYDRANT AT 49 ARUNDEL ROAD W/1000'
BOATSWAIN LANE	1000	6-22 BOATSWAIN LANE HYDRANT AT CUL-DE-SAC W/1000'
BRIARWOOD LANE	1500	3-16 BRAIRWOOD LANE HYDRANT AT SCHOOL AND WASHINGTON COURT W/1000'
BRIGGS WAY	1500	HYDRANTS LOCATED MAIN STREET AND OLD CAPE ROAD AND 133 MAIN STREET W/1000'
BROADWAY	1500	3-12 BROADWAY HYDRANT AT HAYWARD AND KINGS HIGHWAY W/1000'
BROOKS STREET		4-6 BROOKS STREET DRY HYDRANT AT 3 SHORE FARM LANE W/1500'
	DH	250-500 gpm, 250 gpm 2 hours
	1500	HYDRANT AT LANDS END ROAD AND PADDY CREEK HILL ROAD W/3000'

BROOKSIDE DRIVE	1000	1-12 BROOKSIDE DRIVE HYDRANT AT 9 BROOKSIDE DRIVE W/1000'
BROWNS LANE	1500	3-9 BROWNS LANE HYDRANT AT 114 WILDES DISTRICT ROAD
BRYANT LANE		2-20 BRANT LANE DRY HYDRANT AT 14 BRYANT LANE W/1000' 38 BRYANT LANE DRY HYDRANT AT 14 BRYANT LANE W/1200'
	DH	250-500 gpm, 250 gpm 4 hours
		43-50 BRYANT LANE DRY HYDRANT AT 8 ROCK MARSH LANE W/1000' 80-89 BRYANT LANE DRY HYDRANT AT 8 ROCK MARSH LANE W/1900'
	DH	250-500 gpm, 250 gpm 4 hours
BUFFLEHEAD LANE	1000	15-24 BUFFLEHEAD LANE HYDRANT AT 22 BUFFLEHEAD LANE W/1000'
BUSTER LANE		1-3 BUSTER LANE DRY HYDRANT AT HIDDEN POND W/2500' DRY HYDRANT
	DH	AT 403 GOOSE ROCKS ROAD W/2400' 250-500 gpm, 250 gpm 4 hours
BUTTONWOOD LANE	1500	4-10 BUTTONWOOD LANE HYDRANT AT BUTTONWOOD AND SCHOOL STREET W/1000'
CAMDEN LANE	1500	HYDRANT AT WILDES DISTRICT & PADDY CREEK HILL W/2100'
CAMPBELL LANE	DH	DRY HYDRANT AT 96 BEACHWOOD AVE W/1000' 250-500 gpm, 250 gpm 2 hours
CAPE WOODS ROAD	1000	24 CAPE WOODS ROAD HYDRANT AT BOATSWAIN LANE AND CAPE WOODS W/2000'
CAPESTONE DRIVE	1500	8 CAPESTONE DRIVE HYDRANT AT 102 MAIN STREET W/1000'
CAROL LANE		1-6 CAROL LANE DRY HYDRANT AT 3 SHORE FARM LANE W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
	1500	HYDRANT AT LANDS END ROAD AND PADDY CREEK HILL ROAD W/2500'
CENTRAL AVENUE	750 1000	5-10 CENTRAL AVE HYDRANT HYDRANTS AT 4 AND 9 ON OLD 8" MAIN, BEST HYDRANT AT 11 OLD FORT AVE W/1500'
CHART HOUSE ROAD	750	HYDRANT AT 317 OCEAN AVE Hydrant
CHESTNUT STREET		3-14 CHESTNUT STREET HYDRANTS AT 33 OCEAN AVE AND CORNER
	1500	SCHOOL AND MAINE STREET W/1000'
CHURCH STREET	1500	4-10 CHURCH STREET HYDRANT AT 4 CHURCH STREET W/1000'
CLARK ROAD	1000	6 CLARK ROAD HYDRANT AT PROCTOR AND WILDWOOD AVE W/1000'
CLEAVES AVENUE	1500	3-16 CLEAVES AVE HYDRANT AT HAYWARD AND KINGS HIGHWAY W/1000'
CLEMENT HUFF ROAD	1500	9-16 CLEMENT HUFF ROAD HYDRANTS AT 150 AND 170 MAIN STREET W/1000' DRY HYDRANT AT 6 CLEMENT HUFF ROAD W/1000' 39-41 CLEMENT HUFF RD DRY HYDRANT AT 6 CLEMENT HUFF RD W/1700' 44-59 CLEMENT HUFF RD DRY HYDRANT AT 6 CLEMENT HUFF RD W/2500'
	DH	250-500 gpm, 250 gpm 4 hours
CLOVER LEAF FARM ROAD		8 CLOVER LEAF FARM RD DRY HYDRANT AT REAR OF STRUCTURE W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
COFFIN LANE	1000	HYDRANT AT PROCTOR ROAD AND WILDWOOD AVE
COLE BENSON ROAD		2-15 COLE BENSON ROAD DRY HYDRANT AT GUINEA AND COLE BENSON ROAD W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
		36-63 COLE BENSON ROAD DRY HYDRANT AT SHALLOW POND AT 43 COLE BENSON ROAD, DRY HYDRANT AT COLE BENSON AND GUINEA W/3100'
	DH	250-500 gpm, 250 gpm 2 hours
COLONY AVE		8-16 COLONY AVE HYDRANTS AT SOUTH MAINE & ARLINGTON
	1000	OCEAN & COLONY AVE W/1000'
COMMUNITY HOUSE	750 750	3-16 HYDRANT AT PROCTOR & WILDWOOD AVE 17-21 HYDRANT AT COMMUNITY HOUSE ROAD AND SKYLINE DRIVE+
CORNBROOK LANE	1000 1000 1000	8-18 CORNBROOK LANE HYDRANT AT 20 WILDES DISTRICT ROAD W/1500' 26-30 CORNBROOK LANE HYDRANT AT 20 WILDES DISTRICT RD W/2500' 36 CORNBROOK LANE HYDRANT AT 20 WILDES DISTRICT ROAD W/3000'
COTTAGE AVENUE	1500	5-10 COTTAGE AVE HYDRANT AT NORWOOD AND KINGS HIGHWAY W/1000'
COYOTE LANE		4-8 COYOTE LANE DRY HYDRANT AT 112 BEACHWOOD CORNER OF KAYZEELANE W/2000'

	DH	250-500 gpm, 250 gpm 2 hours
CRANBERRY LANE		8-14 CRANBERRY LANE DRY HYDRANT AT 14 CRANBERRY LANE W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
CREEK SIDE	750	3-9 CREEKSIDE HYDRANT AT 22 TURBATS CREEK ROAD W/1000'
CRESCENT AVENUE	1500	2-23 CRESENT AVE HYDRANT AT BARTLETT AND KINGS HIGHWAY AND 252
CRESTVIEW LANE	750	3-6 CRESTVIEW LANE HYDRANT AT 48 WILDES DISTRICT ROAD W/1100'
CROSS STREET	1500	HYDRANT AT SPRING & CROSS
CROW RIDGE ROAD		DRY HYDRANT AT 88 GOOSE ROCKS ROAD MAX LAY 2000'
	DH	250-500 gpm, 250 gpm 4 hours
DAISEY LANE	750	1-6 DAISEY LANE WITHIN 1000' HYDRANT AT 44 WILDES DISTRICT ROAD
DEERFIELD LANE		25 TO 45 DEERFIELD LANE DRY HYDRANT AT 236 BEACHWOOD AVE W/2900'
	DH	500-750 GPM, 250 GPM 4 hours
DICKINSON LANE	1500	4-10 DICKINSON LANE HYDRANT AT 150 MAIN STREET W/1000'
DOCK SQUARE		1-54 DOCK SQUARE HYDRANT IN DOCK SQUARE AND CORNER CROSS ST
	4000	Area flow 4000 GPM
DORRANCE ROAD	1500	2-14 DORRANCE ROAD HYDRANT AT HAYWARD AND KINGS HIGHWAY W/1000'
DOVER LANE	1000	2-8 DOVER LANE HYDRANT AT DOVER, OLD FORT AVE, HAVERHILL ST W/1000'
DRAGONFLY LANE	750	10-20 DRAGONFLY LANE HYDRANT AT 22 TURBATS CREEK ROAD W/1000'
DUCKWOOD LANE		4-12 DUCKWOOD LANE DRY HYDRANT AT 64 BEACHWOOD AVE W/1500'
	DH	250-500 gpm, 250 gpm 2 hours
DYKE ROAD	1500	3-41 DYKE ROAD HYDRANT AT 22 DYKE ROAD W/1000'
	1500	55-57 DYKE ROAD HYDRANT AT 22 DYKE ROAD W/1600'
	1500	71 DYKE ROAD HYDRANT AT 22 DYKE ROAD W/1700'
	750	Seasonal hydrant at Dyke and Mills Road
EAST AVENUE	1000	3-20 EAST AVE HYDRANTS AT EAST AVE AND OCEAN AVE, AND 10 EAST AVE W/1000
EBS COVE LANE	750	HYDRANT AT NEHOC LANE AND TURBATS CREEK ROAD W/1000'
EDGEWOOD AVENUE	1500	2-18 EDGEWOOD AVE HYDRANTS AT 991 KINGS HIGHWAY (TIDES INN)
	1000	AND EDGEWOOD AND WILDWOOD AVE W/1000'
EEL BRIDGE LANE	1500	6-14 EEL BRIDGE LANE HYDRANTS AT 11 AND 23 MILLS ROAD W/1000'
ELIZABETHAN DRIVE	750	1-8 ELIZABETHIAN DRIVE HYDRANT AT WINDEMERE PLACE AND OCEAN AVE W/1000'
	750	9-25 ELIZABETHIAN DRIVE HYDRANT AT WINDEMERE PLACE AND OCEAN AVE W/1500'
		Dry Hydrant at 21 ELIZABETHIAN DRIVE
	DH	250-500 gpm, 250 gpm 4 hours
ELM STREET	1500	1-12 ELM STREET HYDRANT AT ELM AND MAINE AND ELM AND OCEAN AVE BOTH W/1000'
ELWYN LANE	1500	HYDRANT AT 1130 KINGS HIGHWAY W/1000'
ENDCLIFFE ROAD	750	1-16 ENDCLIFF ROAD HYDRANT AT OCEAN AND ENDCLIFF W/1000'
EVENING PLACE	1500	5-16 EVENING PLACE HYDRANT AT 127 SCHOOL STREET W/1000'
FAIRFIELD HILL		15-20 FAIRFIELD HILL ROAD DRY HYDRANT AT 23 FAIRFIELD HILL ROAD W/1200'
	DH	250-500 gpm, 250 gpm 2 hours no water in summer
		DRY HYDRANT AT 111 LOG CABIN ROAD 1400' TO START OF ROAD
	DH	250-500 gpm, 250 gpm 4 hours
FIELD POINT ROAD		10-14 FIELD POINT ROAD HYDRANT AT 2 FIELD POINT ROAD W/1000'
	750	24 FIELD POINT ROAD HYDRANT AT 2 FIELD POINT ROAD W/1200'
FISHERS LANE	1500	4-18 FISHERS LANE HYDRANT AT FISHERS AND PIER ROAD W/1000'
	1500	21-29 FISHERS LANE HYDRANT AT 21 FISHERS LANE W/1000'
FOREST LANE		15-20 DRY HYDRANT AT 178 GUINES ROAD W/1500'
	DH	250-500 gpm, 250 gpm 4 hours
FOX RUN	750	5 FOX RUN HYDRANT AT 10 TOUCHSTONE DRIVE W/1000'
	750	22-26 FOX RUN HYDRANT AT 10 TOUCHSTONE DRIVE W/1500'

FOBERRY LANE	1500 1000	3-9 FOXBERRY LANE HYDRANTS AT OLD CAPE AND GROVE AND FOXBERRY AND GROVE
GEORGE LANE	1500	HYDRANT AT LANDS END ROAD AND WILDES DISTRICT ROAD W/2000'
GLAZIER LANE	1500 1000	3-5 GLAZIER LANE HYDRANTS AT 251 KINGS HIGHWAY (TIDES) AND EDGEWOOD AND WILDWOOD AVE W/1000'
GOOSEFAIR	750	4-28 GOOSEFAIR HYDRANT AT 25 GOOSEFAIR W/1000'
GOOSE ROCKS ROAD		11-12 GOOSE ROCKS ROAD DRY HYDRANT AT 18 GOOSE ROCKS ROAD W/1000' 43 GOOSE ROCKS ROAD DRY HYDRANT AT END OF DRIVEWAY 75-107 GOOSE ROCKS ROAD DRY HYDRANT AT 88 GOOSE ROCKS ROAD W/1000' 117-125 GOOSE ROCKS ROAD DRY HYDRANT AT 88 GOOSE ROCKS ROAD W/1500' 131-174 GOOSE ROCKS ROAD DRY HYDRANT AT 151 GOOSE ROCKS ROAD W/1100' 181-200 GOOSE ROCKS ROAD DRY HYDRANT AT 197 GOOSE ROCKS ROAD W/1000' 221 GOOSE ROCKS ROAD DRY HYDRANT AT 293 ARUNDEL ROAD W/1000' 232 GOOSE ROCKS ROAD DRY HYDRANT AT 294 ARUNDEL ROAD W/1000' 240 GOOSE ROCKS ROAD DRY HYDRANT AT 293 ARUNDEL ROAD A 1900' LAY 283-289 GOOSE ROCKS ROAD DRY HYDRANT AT 286 GOOSE ROCKS ROAD W/1000' 292-320 GOOSE ROCKS ROAD DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/1000' 331 GOOSE ROCKS ROAD DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/1400' 332-336 GOOSE ROCKS ROAD DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/1500' 337 GOOSE ROCKS ROAD DRY HYDRANT AT 286 GOOSE ROCKS ROAD W/2500' 338 GOOSE ROCKS ROAD DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/1500' 341-342 GOOSE ROCKS ROAD DRY HYDRANT IN HIDDEN POND W/1500' DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/1800' 345 GOOSE ROCKS ROAD DRY HYDRANT AT DRY HYDRANT IN HIDDEN POND W/1500' DRY HYDRANT 305 GOOSE ROCKS ROAD W/2100' 352 GOOSE ROCKS ROAD DRY HYDRANT AT DRY HYDRANT IN HIDDEN POND W/1500' DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/2300' 355 GOOSE ROCKS ROAD DRY HYDRANT AT DRY HYDRANT IN HIDDEN POND W/1500' DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/2500' 356-366 GOOSE ROCKS ROAD DRY HYDRANT AT DRY HYDRANT IN HIDDEN POND W/1500' DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/2600' 384-420 GOOSE ROCKS ROAD DRY HYDRANT AT 403 GOOSE ROCKS ROAD W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
GRANDVIEW AVENUE	1000 1000	2-12 GRANDVIEW AVE HYDRANTS AT GRANDVIEW AND SOUTH MAINE AND 116 OCEAN AVE (KENNEBUNK RIVER CLUB) BOTH W/1000'
GRANITE HEIGHTS		8-30 GRANITE HEIGHTS DRY HYDRANT AT 20 GRANITE HEIGHT W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
		DRY HYDRANT AT 145 ARUNDEL ROAD W/1500'
	DH	250-500 gpm, 250 gpm 4 hours
GRAVELLY BROOK		57-59 GRAVELLY BROOK ROAD DRY HYDRANT PARKING LOT OF 59 GRAVELLY BROOK ROAD
	DH	250-500 gpm, 250 gpm 2 hours
		86-92 DRY HYDRANT AT STONE ROAD BRIDGE W/1900'
	DH	250-500 gpm, 250 gpm 4 hours
		DRY HYDRANT AT HUTCHINS SCHOOL BRIDGE W/3300'
	DH	250-500 gpm, 250 gpm 4 hours
GREENE STREET	1500 1500	5-11 GREENE STREET HYDRANTS AT GREENE AND MAINE STREET, GREENE AND OCEAN AVE W/1000' GREENE AND PLEASANT
		3-6 GRIER ROAD HYDRANT AT 59 LANGSFORD ROAD ALL STRUCTURES

	750	WITH 1000' HYDRANT
GROVE STREET	1500	5-30 GROVE STREET HYDRANT AT OLD CAPE AND GROVE
	1000	AND GROVE AND FOXBERRY W/1000'
GUINEA ROAD		6-15 GUINEA ROAD DRY HYDRANT AT 151 GOOSE ROCKS ROAD W/1000'
		33 GUINEA ROAD DRY HYDRANT AT 151 GOOSE ROCKS ROAD W/1500'
	DH	250-500 gpm, 250 gpm 2 hours
		64 -135 GUINEA ROAD DRY HYDRANT AT 47 GUINEA ROAD W/2200'
		136 GUINEA ROAD DRY HYDRANT AT 114 GUINEA ROAD W/1100' LAY
		139 GUINEA ROAD DRY HYDRANT AT 114 GUINEA ROAD W/1000' LAY
		149 GUINEA ROAD DRY HYDRANT AT 114 GUINEA ROAD W/2000'
	DH	250-500 gpm, 250 gpm 2 hours
		169-195 GUINEA ROAD DRY HYDRANT AT 178 GUINEA ROAD W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
GULL WAY	1500	HYDRANT AT 153 WILDES DISTRICT ROAD
HALCYON WAY	750	3-16 HALCYON WAY HYDRANT AT OCEAN AVE AND HALCYON WAY A MAX LAY OF 1000'
	750	AND HYDRANT AT 9 HALCYON WAY ONLY ONE HYDRANT CAN BE USED
HARBOR DRIVE		10-15 HARBOR DRIVE DRY HYDRANT AT 19 HARBOR DRIVE
	DH	250-500 gpm, 250 gpm 2 hours
		DRY HYDRANT AT 3 SHORE FARMS LANE,
	DH	250-500 gpm, 250 gpm 2 hours
	1500	HYDRANT AT PADDY CREEK HILL ROAD AND LANDS END ROAD 1500' LAY
		TO THE THREE WAY SPLIT AND 1100 MORE FEET TO END OF ROAD (2600' LAY TOTAL)
HARMONY LANE	1500	HYDRANT AT 101 MAIN STREET
HARRISON LANE	1500	1-10 HARRISON LANE HYDRANT AT 491 KINGS HIGHWAY W/1000'
HARWOOD DRIVE		2-19 HARWOOD DRIVE DRY HYDRANT AT 3 SHORE FARMS LANE,
	DH	250-500 gpm, 250 gpm 2 hours
	1500	HYDRANT AT PADDY CREEK HILL ROAD AND LANDS END ROAD 1500' LAY
		TO THE THREE WAY SPLIT AND 1100 MORE FEET TO END OF ROAD (3100' LAY TOTAL)
HAVERHILL AVENUE	1000	14 HAVERHILL AVE HYDRANT AT HAVERHILL AND OLD FORT AVE W/1000'
HAYWARD AVENUE	1000	3-11 HAYWARD AVE HYDRANT AT HAYWARD AND KINGS HIGHWAY W/1000'
	1000	HIGHWAY BOTH W/1000'
HICKORY LANE		1-10 HICKORY LANE DRY HYDRANT AT 236 BEACHWOOD AVE W/1600'
	DH	250-500 gpm, 250 gpm 2 hours
		DRY HYDRANT AT 172 MILLS ROAD W/3600'
	DH	250-500 gpm, 250 gpm 4 hours
HIDDEN MARSH	1500	9 HIDDEN MARSH LANE HYDRANT AT NORTH AND BEACHWOOD W/1000'
HIDDEN POND LANE		MULTIPLE COTTAGES 2 DRY HYDRANTS ON PREMISES
	DH	250-500 gpm, 250 gpm 4 hours
HIGH POINT DRIVE	1500	6-24 HIGH POINT DRIVE HYDRANTS 80 WILDES DISTRICT ROAD
	1500	AND HIGHPOINT ROAD AND SADDLEWAY WITHIN A 1000'
HIGH STREET	1500	2-10 HIGH STREET HYDRANTS AT 9 SCHOOL AND 25 SCHOOL BOTH W/1000'
HIGH TIDE ROAD		1-33 HIGH TIDE ROAD DRY HYDRANT AT 8 CLOVER LEAF FARM ROAD W/1400'
		46-67 HIGH TIDE ROAD DRY HYDRANT AT 8 CLOVER LEAF FARM ROAD W/1400'
	DH	250-500 gpm, 250 gpm 2 hours
HILLSIDE AVENUE	1000	3-4 HILLSIDE AVE HYDRANT AT 1176 KINGS HIGHWAY W/1000'
HUNTERS WAY	1000	1-8 HUNTERS WAY HYDRANT AT 68 MILLS ROAD W/1000'
IRELAND WAY		RIGHT OF WAY OFF WILDWOOD AVE
ISLAND VIEW LANE		RIGHT OF WAY OFF SAND POINT ROAD
IVY LANE	1000	HYDRANT AT 2 ARLINGTON AVE,

JASONS WAY	DH	2-26 JASONS WAY DRY HYDRANT AT 7 THE LONG AND WINDING ROAD W/2400' 250-500 gpm, 250 gpm 2 hours
JEFFERYS WAY	1500 1500	4-6 JEFFERYS WAY HYDRANT AT HAYWARD AND KINGS HIGHWAY AND 1083 KINGS HIGHWAY BOTH W/1000'
JENNISON DRIVE	DH	12-15 JENNISON DRIVE DRY HYDRANT AT 12 WINTER HARBOR ROAD MAXIMUM LAY 1500' 250-500 gpm, 250 gpm 2 hours
JOSIAH CURTIS LANE	1000	2-8 JOSIAH CURTIS LANE HYDRANT AT COLONY AVE AND OCEAN AVE W/1000'
JUNIPER KNOLL	1000	1-7 JUNIPER KNOLL LANE HYDRANT AT 6 SOUTH MAIN STREET W/1000'
KAYZEE LANE	DH	6-8 KAYZEE LANE DRY HYDRANT AT ENTERANCE TO KAYZEE LANE . 250-500 gpm, 250 gpm 2 hours
KENNETH LANE	1500	KENNETH LANE HYDRANT AT GROVE & OLD CAPE ROAD W/2900'
KINGS HIGHWAY	1500 1500 1500 1500 1500 1500 1500 1500 1500 1500 1500	401-443 KINGS HIGHWAY HYDRANT AT 443 KINGS HIGHWAY W/1000' 448-553 KINGS HIGHWAY HYDRANT AT 491 KINGS HIGHWAY W/1000' 568-586 KINGS HIGHWAY HYDRANT AT 575 KINGS HIGHWAY W/1000' 570-653 KINGS HIGHWAY HYDRANT AT 653 KINGS HIGHWAY W/1000' 657-722 KINGS HIGHWAY HYDRANT AT 729 KINGS HIGHWAY W/1000' 729-866 KINGS HIGHWAY HYDRANT AT 792 KINGS HIGHWAY W/1000' 849-899 KINGS HIGHWAY HYDRANT AT 888 KINGS HIGHWAY W/1000' 932-997 KINGS HIGHWAY HYDRANT AT 991 KINGS HIGHWAY W/1000' 1002-1044 KINGS HIGHWAY HYDRANT AT 1044 KINGS HIGHWAY W/1000' 1045-1084 KINGS HIGHWAY HYDRANT AT 1084 KINGS HIGHWAY W/1000' 1095-1175 KINGS HIGHWAY HYDRANT 1176 KINGS HIGHWAY W/1000'
KINGS LANE	750	2-37 KINGS LANE HYDRANT AT 7 KINGS LANE W/1000'
KITTYS RUN	DH	DRY HYDRANT AT 62 BEACHWOOD AND 26 OLD CAPE ROAD BEST DRY HYDRANT AT 62 BEACHWOOD 2000' LAY TO START OF ROAD 250-500 gpm, 250 gpm 2 hours
LAKE HOUSE LANE	1500	HYDRANT AT LAKE HOUSE LANE AND WILDES DISTRICT ROAD
LANDS END ROAD	1500 1500 DH	5-18 LAND END ROAD HYDRANT AT LANDS END ROAD AND WILDES DISTRICT ROAD W/1000' 28-58 LANDS END ROAD HYDRANT AT LANDS END ROAD AND PADDY CREEK HILL ROAD, 1500' LAY TO THREE WAY SPLIT, THEN 1400' TO END OF ROAD TOTAL LAY 2900' LANDS END ROAD HYDRANT AT LANDS END ROAD AND WILDES DISTRICT ROAD DRY HYDRATE AT 3 SHORE FARM LANE 250-500 gpm, 250 gpm 2 hours
LANGSFORD ROAD	1500 1000 1000 750 750	3-15 LANGSFORD ROAD HYDRANT AT 178 MAIN STREET (CAPE STATION) W/1000' 16-21 LANGSFORD ROAD HYDRANT AT 21 LANGSFORD ROAD W/1000' 28-39 LANGSFORD ROAD HYDRANT AT 21 LANGSFORD ROAD W/1000' 42-56 LANGSFORD ROAD HYDRANT AT 39 LANGS FORD ROAD W/1000' 58-64 LANGSFORD ROAD HYDRANT AT 59 LANGS FORD ROAD W/1000'
LAUREL ROAD	1500	5-10 LAUREL ROAD HYDRANT AT 70 SCHOOL STREET(WASHINGTON COURT) W/1000'
LEDGE ROAD	1500	1-18 LEDGE ROAD HYDRANT AT 114 WILDES DISTRICT ROAD W/1000'
LEDGE VIEW LANE	DH	DRY HYDRANT AT 14 BRYANT LANE MAX LAY 1400' 250-500 gpm, 250 gpm 2 hours
LILAC LANE	DH	15-17 LILAC LANE DRY HYDRANT AT 106 BEACHWOOD AVE A 1500' LAY 250-500 gpm, 250 gpm 2 hours
LITTLE RIVER WAY	DH	PRIVATE ROAD DRY HYDRANTS AT 8 MARSH ROCK LANE ABOUT A 2000' LAY 250-500 gpm, 250 gpm 4 hours
LOCKE STREET	1500 1500	1-20 LOCKE STREET HYDRANT AT 32 NORTH STREET (PORT VILLAGE STA w/1000' Hydrant at Locke & Oak
MAGNOLIA DRIVE	1500	3-22 MAGNOLIA DRIVE HYDRANT AT 11 MAGNOLIA DRIVE WITH IN 1000'
MAIN STREET	1500	101-115 MAIN STREET HYDRANT AT 102 MAIN STREET W/1000'

	1500	130-150 MAIN STREET HYDRANT AT 133 MAIN STREET W/1000'	
	1500	151-173 MAIN STREET HYDRANT AT 150 MAIN STREET W/1000'	
MAINE STREET	1500	2-8 MAINE STREET HYDRANT AT MAIN AND NORTH STREET, MAINE AND SPRING STREET BOTH WITHIN 1000'	
	1000	8-24 HYDRANT AT 18 MAINE (LIBRARY), MAINE AND SPRING STREET BOTH WITHIN 1000'	
	1500	25-30 HYDRANT AT MAINE AND SCHOOL STREET AND 18 MAINE (LIBRARY),BOTH 1000'	
	1500	31-36 HYDRANT AT MAINE OPPOSITE PEARL STREET AND SCHOOL STREET AND MAINE ,BOTH WITHIN 1000'	
	1500	38-40 HYDRANT AT MAINE OPPOSITE GREENE STREET AND MAINE STREET OPPOSITE PEARL STREET ,BOTH WITHIN 1000'	
	1500	41 HYDRANT AT MAINE OPPOSITE SOUTH STREET AND MAINE OPPOSITE GREENE STREET ,BOTH WITHIN 1000'	
	1500	41-47 HYDRANT AT MAINE OPPOSITE SOUTH STREET AND MAINE OPPOSITE GREENE STREET ,BOTH WITHIN 1000'	
	1500	41-47 HYDRANT AT MAINE OPPOSITE SOUTH STREET AND MAINE OPPOSITE GREENE STREET ,BOTH WITHIN 1000'	
	1000	48-59 HYDRANT AT MAINE AND WILDES DISTRICT ROAD AND MAINE OPPOSITE SOUTH STREET ,BOTH WITHIN 1000'	
MALINGWOOD LANE	DH	3-37 MALINGWOOD LANE DRY HYDRANT AT 64 BEACHWOOD AVE MAX LAY IS 2500', SEASONAL DRY HYDRANT AT 10 MALINGWOOD LANE 250-500 gpm, 250 gpm 2 hours	
MAPLEWOOD DRIVE	1000	3-10 MAPLEWOOD DRIVE HYDRANT AT 44 WILDES DISTRICT RD W/1000'	
MARLEYS WAY	DH	DRY HYDRANT AT TYLER BROOK AND MILLS ROAD W/1000' 500 GPM FOR 4 HOURS	
MARSHALL POINT RD	1000	5-6 MARSHALL POINT ROAD HYDRANT AT 50 AND 62 MILLS ROAD BOTH WITHIN 1000'	
	1500	73-77 MARSHALLS POINT ROAD HYDRANT AT 73 MARSHALL POINT ROAD WITHIN 1000'	
	1500	103-111 MARSHALLS POINT ROAD HYDRANT AT 130 MARSHALL POINT ROAD W/1400'	
	1500	115-136 MARSHALLS POINT ROAD HYDRANT AT 130 MARSHALLS POINT ROAD w/1000'	
MARSH MADNESS LN	DH	20 MARSH MADNESS LANE DRY HYDRANT AT TYLER BOOK AND MILLS ROAD W/1400' 250-500 gpm, 250 gpm 4 hours	
MARSHVIEW CIRCLE	750	1-8 MARSHVIEW CIRCLE HYDRANT AT 15 COMMUNITY HOUSE RD W/1000'	
MAST COVE LANE	1500	2-5 MAST COVE LANE HYDRANT AT 18 MAINE STREET W/1000'	
MCKENNEY LANE	1500	3-9 MCKENNEY LANE HYDRANT AT 114 WILDES DISTRICT ROAD W/1000'	
	1500	18 MCKENNEY LANE HYDRANT AT 114 WILDES DISTRICT ROAD W/1200'	
MERRYMEETING LANE	1000	9-11 MERRYMEETING LANE HYDRANT AT 56 MAINE STREET W/1000'	
MESERVES LANE	1500	2-7 MESERVES LANE HYDRANT AT 34 NORTH STREET (OPPOSITE LANE) W/1000'	
MICHAELS WAY	DH	DRY HYDRANT AT 88 GOOSE ROCKS ROAD W/1000, 500 GPM FOR 2 HOURS	
MILL LANE	1500	2-8 MILL LANE HYDRANT AT MILL LANE AND NORTH STREET W/1000'	
MILLS ROAD	1500	1-11 MILLS ROAD HYDRANT AT 172 MAIN AND 11 MILLS ROAD BOTH W/1000'	
	1500	12-23 MILLS ROA HYDRANT AT 11 MILLS ROAD W/1000'	
	1500	24-43 MILLS ROAD HYDRANT AT 23 MILLS ROAD W/1000'	
	1000	43-50 MILLS ROAD HYDRANT AT 43 MILLS ROAD W/1000'	
	1000	51-68 MILLS ROAD HYDRANT AT 50 MILLS ROAD W/1000'	
	1000	69-80 MILLS ROAD HYDRANT AT 68 MILLS ROAD W/1000'	
	1000	90 MILLS ROAD HYDRANT AT 68 MILLS ROAD W/1200'	
	1000	98 MILLS ROAD HYDRANT AT 25 GOOSEFAIR W/1200'	
	1000	106 MILLS ROAD HYDRANT AT 25 GOOSEFAIR W/1500'	
			110 MILLS ROAD DRY HYDRANT AT TYLER BROOK AND MILLS ROAD W/1700'
			116-120 MILLS ROAD DRY HYDRANT AT TYLER BROOK AND MILLS W/1200'
		128-193 MILLS ROAD DRY HYDRANT AT BATSON RIVER AND MILLS ROAD W/1000'	

		194-196 MILLS ROAD DRY HYDRANT AT BATSON RIVER AND MILLS ROAD W/1200' 204 MILLS ROAD DRY HYDRANT AT BATSON RIVER AND MILLS ROAD W/1600' 233-236 MILLS ROAD DRY HYDRANT AT BATSON RIVER AND MILLS ROAD W/3300'
	DH	250-500 gpm, 250 gpm 4 hours
		262 MILLS ROAD DRY HYDRANT AT CONDO COMPLEX W/2000' 272 MILLS ROAD DRY HYDRANT AT CONDO COMPLEX W/1000' W/1000' 277-278 MILLS ROAD DRY HYDRANT AT CONDO COMPLEX W/1000' W/2000'
	DH	250-500 gpm, 250 gpm 4 hours
		294 MILLS ROAD DRY HYDRANT AT 409 GOOSE ROCKS ROAD W/2500' SEASONAL 750 GPM HYDRANT AT DKE ROAD INTERSECTION
	DH	250-500 gpm, 250 gpm 4 hours
		332 MILLS ROAD DRY HYDRANT AT 12 WINTER HARBOR ROAD W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
		342-347 MILLS ROAD DRY HYDRANT AT NEW BIDDEFORD RD AND MILLS RD W/1500' 348-351 MILLS ROAD DRY HYDRANT AT NEW BIDDEFORD RD AND MILLS RD W/1300' 352 MILLS ROAD DRY HYDRANT AT NEW BIDDEFORD RD AND MILLS RD W/1200' 355-396 MILLS ROAD DRY HYDRANT AT NEW BIDDEFORD RD AND MILLS RD W/1300' 405 MILLS ROAD DRY HYDRANT AT NEW BIDDEFORD RD AND MILLS RD W/1600' 22 MILLS ROAD DRY HYDRANT AT 14 BRYANT LANE W/1000' 424-435 MILLS ROAD DRY HYDRANT AT 8 CLOVER LEAF FARM ROAD W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
MITCHELLS WAY	1500	HYDRANT AT 1084 KINGS HIGHWAY W/1000'
MONADNOCK LANE	1000	5 MONADNOCK LANE HYDRANT IS AT AGAMENTICUS AND SUMAC 200' IN FROM FISHERS LANE w/1000'
MOOSE ROCKS ROAD		7 MOOSE ROCKS ROAD DRY HYDRANT AT 88 GOOSE ROCKS ROAD W/1000' 12-30 MOOSE ROCKS ROAD DRY HYDRANT AT 88 GOOSE ROCKS ROAD W/1000' 40 MOOSE ROCKS ROAD DRY HYDRANT AT 88 GOOSE ROCKS ROAD W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
MOUNT KINEO ROAD		2-42 MOUNT KINEO ROAD DRY HYDRANT AT 21 MOUNT KINEO RD W/1000' 43 MOUNT KINEO DRY HYDRANT AT 21 MOUNT KINEO ROAD W/1100' 47-49 MOUNT KINEO DRY HYDRANT AT 21 MOUNT KINEO ROAD W/1400' 56 MOUNT KINEO DRY HYDRANT AT 21 MOUNT KINEO ROAD W/1800'
	DH	250-500 gpm, 250 gpm 2 hours
NEHOC LANE	750	8-18 NEHOC LANE HYDRANT AT NEHOC AND TURBATS CREEK RD W/1000'
NETTIE LANE		DRY HYDRANT AT MILLS ROAD AND NEW BIDDEFORD ROAD 1600' TO START OF STREET
	DH	250-500 gpm, 250 gpm 2 hours
NEW ADAMS ROAD		8-16 NEW ADAMS ROAD DRY HYDRANT AT 35 OXPLOW LANE W/1500' 17-28 NEW ADAMS ROAD DRY HYDRANT AT 35 OXPLOW LANE W/2000'
	DH	250-500 gpm, 250 gpm 2 hours
NEW BIDDEFORD RD	1500	2-18 NEW BIDDEFORD ROAD HYDRANT AT 292 KINGS HIGHWAY W/1000
	1500	19-39 NEW BIDDEFORD ROAD HYDRANT AT 18 NEW BIDDEFORD ROAD W/1000'
	1500	47-68 NEW BIDDEFORD ROAD HYDRANT AT 34 NEW BIDDEFORD ROAD
		34 DRY HYDRANT AT REAR 49 NEW BIDDEFORD ROAD W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
NORTH STREET	1500	2-16 NORTH STREET HYDRANT AT 9 NORTH STREET W/1000'
	1500	17-34 NORTH STREET HYDRANT AT 16 NORTH STREET W/1000'
	1500	35-49 NORTH STREET HYDRANT AT 34 NORTH STREET W/1000'
	1500	57-77 NORTH STREET HYDRANT AT 66 NORTH STREET W/1000'
	1500	102-121 NORTH STREET HYDRANT AT 140 NORTH STREET W/1000'

	1500	122-143 NORTH STREET HYDRANT AT 140 NORTH STREET W/1000'
NORTHWOOD DRIVE	1500	15-18 NORTHWOOD DRIVE HYDRANT AT 79 NORTH STREET W/1000'
		41-45 NORTHWOOD DRIVE DRY HYDRANTS AT 20 & 25 NORTHWOOD DRIVE W/1000'
		47-48 NORTHWOOD DRIVE DRY HYDRANT AT 25 NORTHWOOD DRIVE W/1200'
		51 NORTHWOOD DRIVE DRY HYDRANT AT 25 NORTHWOOD DRIVE, W/1300'
		54 NORTHWOOD DRIVE DRY HYDRANT AT 25 NORTHWOOD DRIVE W/1400'
		63 NORTHWOOD DRIVE DRY HYDRANT AT 25 NORTHWOOD DRIVE W/1900'
	DH	250-500 gpm, 250 gpm 2 hours
NORWOOD LANE	1500	1-24 NORWOOD LANE HYDRANT AT 653 KINGS HIGHWAY OPPOSITE NORWOOD LANE W/1000'
OAK GROVE LANE		8-12 OAK GROVE LANE DRY HYDRANT ON SHALLOW POND AT INTERSECTION OF COLE BENSON ROAD AND OAK GROVE W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
OAK RIDGE ROAD		2-19 OAK RIDGE ROAD DRY HYDRANT AT 305 GOOSE ROCKS RD (ACROSS STREET) W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
		36 OAK RIDGE ROAD DRY HYDRANT ACROSS STREET FROM DRIVEWAY W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
		57-77 OAK RIDGE ROAD DRY HYDRANT AT 57 OAK RIDGE ROAD W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
		79-99 OAK RIDGE ROAD DRY HYDRANT AT 83 OAK RIDGE ROAD W/1000'
		127-132 OAK RIDGE ROAD DRY HYDRANT AT 83 OAK RIDGE ROAD W/2500'
		152-158 OAK RIDGE ROAD DRY HYDRANT AT 83 OAK RIDGE ROAD W/3600'
		164 OAK RIDGE ROAD DRY HYDRANT AT 83 OAK RIDGE ROAD W/3700'
		167 OAK RIDGE ROAD DRY HYDRANT AT 83 OAK RIDGE ROAD W/4200'
	DH	250-500 gpm, 250 gpm 4 hours
OAK RUN	1500	3-10 OAK RUN HYDRANT AT PADDY CREEK HILL ROAD AND WILDES DISTRICT WITH IN 1000'
OAK STREET	1500	2-20 OAK STREET HYDRANT AT 1 OAK AND 15 OAK BOTH ON SAME 8" DEAD END MAIN W/1000'
	1500	1 Oak Street
	1500	18 OAK STREET
OAKWOOD DRIVE	750	3-20 OAKWOOD DRIVE HYDRANT AT HALCYON AND OCEAN AVE W/1000'
		23 OAKWOOD DRIVE DRY HYDRANT AT 20 OAKWOOD DRIVE W/1000'
		44 OAKWOOD DRIVE DRY HYDRANT AT 37 OAKWOOD DRIVE W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
OBED LANE	1500	HYDRANT AT 98 WILDES DISTRICT ROAD W/1000'
OCEAN AVENUE		2-13 OCEAN AVE HYDRANTS AT 5 DOCK SQUARE W/1000'
		13-21 OCEAN AVE HYDRANT AT CORNER OF OCEAN AND UNION STREET WITHIN 1000'
	3000+	Area flow 3000 plus gpm
	1500	24-36 OCEAN AVE HYDRANT BETWEEN CHESTNUT AND ELM W/1000'
		37-50 OCEAN AVE HYDRANTS OCEAN NEAR ELM STREET CORNER OF OCEAN AND PEARL
	1500	ALL WITHIN 1000'
	1500	51-64 OCEAN AVE HYDRANT CORNER OF OCEAN AND GREEN STREET W/1000'
	1000	66-70 OCEAN AVE HYDRANT 64 OCEAN W/1000'
	1000	75-99 OCEAN AVE HYDRANT CORNER OF OCEAN AND EAST AVE W/1000'
	1000	100-129 OCEAN AVE HYDRANT AT 116 OCEAN AVE (KENNEBUNK RIVER CLUB) W/1000'
	1000	133-150 OCEAN AVE HYDRANT AT OCEAN AVE AND COLONY AVE W/1000'
	450	156-170 OCEAN AVE HYDRANT AT 169 OCEAN AVE (ST. ANNES)
	750	172-197 OCEAN AVE HYDRANT AT SUMMIT AND CENTRAL
750	200-210 OCEAN AVE HYDRANT AT 11 SUMMITT AVE WITHIN 1000'	
750	212-216 OCEAN AVE HYDRANT AT 16 SUMMITT AVE WITHIN 1000'	
750	218-228 OCEAN AVE HYDRANT AT 217 OCEAN AVE W/1000'	

	750	232-240 OCEAN AVE HYDRANT AT 226 OCEAN AVE W/1000'
	750	243-253 OCEAN AVE HYDRANT AT 252 OCEAN AVE W/1000'
	750	260 OCEAN AVE HYDRANT AT 252 OCEAN AVE W/1000 TO START OF DRIVEWAY, DRIVEWAY 600'
	750	261-267 OCEAN AVE HYDRANT AT 272 OCEAN AVE W/1000'
	750	271 OCEAN AVE HYDRANT AT 272 OCEAN AVE W/1000'
	750	275-296 OCEAN AVE HYDRANT AT WASHBURN AND OCEAN AVE W/1000'
	750	298-303 OCEAN AVE HYDRANT AT OCEAN AND HALCYON W/1000'
	750	305-325 OCEAN AVE HYDRANT AT 317 OCEAN AVE W/1000'
	750	326-332 OCEAN AVE HYDRANT AT TURBATS CREEK ROAD AND OCEAN AVE W/1000'
OCEAN VIEW AVENUE	750	1-10 OCEAN VIEW AVE HYDRANT AT 11760 KINGS HIGHWAY W/1000'
OLD CAPE ROAD		2 OLD CAPE ROAD DRY HYDRANT AT 64 BEACHWOOD AVE W/1100' 8-10 OLD CAPE ROAD DRY HYDRANT AT 33 OLD CAPE ROAD W/1000' DRY HYDRANT AT 64 BEACHWOOD AVE WITH IN A 1500' LAY 18-25 OLD CAPE ROAD DRY HYDRANT AT 33 OLD CAPE ROAD W/1000'DRY HYDRANT AT 64 BEACHWOOD AVE WITH IN A 2200' LAY 26 OLD CAPE ROAD DRY HYDRANT AT 33 OLD CAPE ROAD WITHIN 1000' LAY DRY HYDRANT AT 64 BEACHWOOD AVE WITH IN A 2400' LAY 30-41 OLD CAPE ROAD DRY HYDRANT AT 33 OLD CAPE ROAD WITHIN 1000' LAY DRY HYDRANT AT 64 BEACHWOOD AVE W/3000' 47-56 OLD CAPE ROAD DRY HYDRANT AT 33 OLD CAPE ROAD WITHIN 2000' LAY HYDRANT AT 103 OLD CAPE ROAD WITH IN A 3100' LAY 57 OLD CAPE ROAD DRY HYDRANT AT 33 OLD CAPE ROAD WITHIN 2000' HYDRANT AT 103 OLD CAPE ROAD W/2300' 61-66 OLD CAPE ROAD DRY HYDRANT AT 33 OLD CAPE ROAD WITHIN 2000' HYDRANT AT 103 OLD CAPE ROAD W/2400'
	DH	250-500 gpm, 250 gpm 2 hours
	1500	68-82 OLD CAPE ROAD HYDRANT AT 103 OLD CAPE ROAD W/2000'
	1500	97-109 OLD CAPE ROAD HYDRANT AT 103 OLD CAPE ROAD W/1000'
	1500	115-121 OLD CAPE ROAD HYDRANT AT 107 MAIN STREET W/1000'
OLD CLUFF ROAD		2-37 OLD CLUFF ROAD DRY HYDRANT AT 26 OLD CLUFF ROAD W/1200' 49-53 OLD CLUFF ROAD DRY HYDRANT AT 26 OLD CLUFF ROAD W/1400' 71-72 OLD CLUFF ROAD DRY HYDRANT AT 26 OLD CLUFF ROAD W/2400' 82 OLD CLUFF ROAD DRY HYDRANT AT 26 OLD CLUFF ROAD W/3300'
	DH	250-500 gpm, 250 gpm 2 hours
OLD FORT AVENUE	1000	2-16 OLD FORT AVE HYDRANTS AT OLD FORD AVE AND HAVERHILL STREETS, AND 11 OLD FORT AVE W/1000'
	1000	
OLD PERKINS ROAD	1500	3-7 OLD PERKINS ROAD HYDRANT 102 MAIN STREET W/1000'
OLD WILDES FARM	1000	6-16 OLD WILDES FARM HYDRANTS AT 88 WILDES DISTRICT ROAD W/1000'
OX PLOW LANE		7-35 OX PLOW LANE DRY HYDRANT AT 35 OX PLOW LANE W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
PADDY CREEK HILL	1500	3-8 PADDY CREEK HILL ROAD HYDRANT AT PADDY CREEK HILL RD AND WILDES DISTRICT RD and
	1500	HYDRANT AT WILDES DISTRICT RD AND PADDY CREEK RD W/1000
PADDY CREEK ROAD	1500	5-15 PADDY CREEK ROAD HYDRANT AT PADDY CREEK ROAD AND WILDES DISTRICT W/1000'
	1500	18-29 PADDY CREEK ROAD HYDRANT AT PADDY CREEK ROAD AND WILDES DISTRICT W/1500'
PEARL STREET	1500	2-12 PEARL STREET HYDRANTS AT PEARL AND OCEAN AND PEARL AND MAINE WITH IN 1000' LAY
PEGS WAY	1500	HYDRANT AT 1084 KINGS HIGHWAY W/1000'
PERKINS LANE	1500	3-10 PERKINS LANE HYDRANT AT WILDES DISTRICT AND LANDS END RD 1500' LAY TO THE THREE WAY SPLIT AND 1200 MORE FEET TO END OF ROAD (2700' LAY TOTAL)

		SECOND WATER SUPPLY DRY HYDRANT AT 3 SHORE FARM LANE (1200' LAY)
	DH	250-500 gpm, 250 gpm 2 hours
PIER ROAD	1500	1-8 PIER ROAD HYDRANT AT 178 MAIN STREET CAPE STATION W/1000'
	1500	9-28 PIER ROAD HYDRANT AT 9 PIER ROAD W/1000' LAY
	1500	29-40 PIER ROAD HYDRANT AT PIER ROAD AND FISHERS LANE W/1000'
	1000	41-48 PIER ROAD HYDRANT AT 40 PIER ROAD W/1000' LAY
	1000	49-63 PIER ROAD HYDRANT AT 48 PIER ROAD W/1000' LAY
	750	74-81 PIER ROAD HYDRANT AT 79 PIER ROAD W/1000' LAY
PINETREE LANE	1000	8-10 PINE TREE LANE HYDRANT AT 68 MILLS ROAD W/1000'
PLEASANT STREET	1500	6-14 PLEASANT STREET HYDRANTS MAINE & PEARL, MAINE & GREENE , MAINE & SOUTH W/1000'
POETS LANE	750	2 POETS LANE HYDRANT AT ENDCLIFFE AND OCEAN W/1000'
	750	16 POETS LANE HYDRANT AT ENDCLIFFE AND OCEAN W/1800'
PORT FARM ROAD	1000	1-12 PORT FARM ROAD HYDRANTS AT 58 AND 44 WILDES DISTRICT ROAD BOTH W/1000'
PORTSIDE DRIVE		7-17 PORTSIDE DRIVE DRY HYDRANT AT 178 GUINEA ROAD W/1800'
	DH	250-500 gpm, 250 gpm 4 hours
PRESCOTT DRIVE	750	1-26 PRESCOTT DRIVE HYDRANT AT 15 COMMUNITY HOUSE DRIVE W/1000'
PRIMROSE LANE	1500	1-2 PRIMROSE LANE HYDRANT ON SCHOOL STREET OPPOSITE WASHINGTON COURT W/1000'
PROCTOR AVENUE	1000	3-18 PROCTOR AVE HYDRANT AT PROCTOR AND WILD WOOD AVE W/1000'
RANKIN LANE	750	1-20 RANKIN LANE HYDRANT AT 317 OCEAN W/1000'
		2 DRY HYDRANTS ON PREMISES
	DH	250-500 gpm, 250 gpm 4 hours
RAVEN ROAD	1500	1-2 RAVEN LANE HYDRANT AT PIER AND FISHERS LANE W/1000'
RECREATION WAY	3000+	HYDRANT AT 25 SCHOOL STREET, 2 ND HYDT JUST BEFORE SEWER TREATMENT PLANT
REDMOND DRIVE	1000	4-12 REDMOND DRIVE HYDRANT AT 68 MILLS ROAD WITHIN 1000'
REID LANE	1000	PRIVATE HYDRANT AT ABOUT 14 REID LANE
REYNOLDS LANE	1500	HYDRANT AT 102 MAIN STREET
RIDGE LANE		5-10 RIDGE LANE DRY HYDRANT AT RIDGE AND COLE BENSON IN A SHALLOW POND W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
RITA ROAD	750	6 RITA ROAD HYDRANT AT 56 TURBATS CREEK ROAD W/1000'
RIVER ROAD	1500	7-37 RIVER ROAD HYDRANT AT 20 RIVER ROAD W/1000'
	1500	37-64 RIVER ROAD HYDRANT AT 56 RIVER ROAD
ROAD TO MISERY		34 ROAD TO MISERY DRY HYDRANT AT 83 OAK RIDGE ROAD A 3700' LAY TO START OF ROAD plus 1700' LAY TO STRUCTURE
	DH	250-500 gpm, 250 gpm 4 hours
ROBERTS LANE		5-10 ROBERTS LANE HYDRANT AT 103 OLD CAPE ROAD, A 1600' LAY TO
	1500	BEGINNING OF ROBERTS LANE, 3200' LAY TO BUILDING
ROBIN LANE	1500	8-11 ROBIN LANE HYDRANT AT 103 OLD CAPE ROAD W/1000'
ROCKMARSH ROAD		21-31 ROCKMARSH ROAD DRY HYDRANT AT 7 ROCKMARSH ROAD W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
ROCKY PASTURE LN.	1000	7-39 ROCKY PASTURE LANE HYDRANT AT WILDES DISTRICT ROAD OR
	1000	WAKEFIELD PASTURE ROAD W/2400'
ROSELEITH LANE	1500	15 ROSELEITH LANE HYDRANT AT 114 WILDES DISTRICT ROAD W/1000'
RUGOSA WAY	1500	HYDRANT AT 1046 KINGS HIGHWAY W/1000'
RUSH POND	1500	HYDRANT AT 491 KINGS HIGHWAY W/1000'
SADDLE WAY	1500	1-9 SADDLE WAY HYDRANT HIGHPOINT ROAD AND SADDLEWAY W/1000'
SALT AIR	750	HYDRANT AT 39 LANGSFORD ROAD W/1000'
SALT MARSH LANE		8-11 SALT MARSH LANE DRY HYDRANT AT 12 WINTER HARBOR ROAD WITHIN 1000'.
	DH	250-500 gpm, 250 gpm 2 hours
SAND DOLLAR LANE		4-11 SAND DOLLAR LANE DRY HYDRANT AT 33 OLD CAPE ROAD W/1000'

	DH	250-500 gpm, 250 gpm 2 hours
SAND POINT ROAD	1500	3-18 SAND POINT ROAD HYDRANT AT 1084 KINGS HIGHWAY W/1000'
	1500	18-29 HYDRANT AT 18 SAND POINT ROAD W/1000'
SANDPIPER LANE	750	3-12 SANDPIPER LANE HYDRANT AT OCEAN AND WASHBURN W/1000'
SANDY COVE ROAD	750	5-15 SANDY COVE ROAD HYDRANT AT 240 OCEAN AVE CORNER OF SANDY COVE W/1000'
SCARGO WAY		DRY HYDRANT LOCATED AT 21 MOUNT KINEO ROAD 1200' TO START OF THE ROAD
	DH	250-500 gpm, 250 gpm 2 hours
SCHOOL STREET	1500	3-26 SCHOOL STREET HYDRANTS AT 9 SCHOOL STREET AND MAINE AT SCHOOL STREET BOTH WITHIN 1000'
	1500	25-26 HYDRANTS AT 9 SCHOOL ST AND 25 SCHOOL ST BOTH W/1000'
	1500	35 HYDRANT AT 36 SCHOOL STREET AND 25 SCHOOL ST. BOTH W/1000'
	1500	43-58 HYDRANTS AT 36 SCHOOL STREET, 11 MAGNOLIA DRIVE, AND 70 SCHOOL STREET ALL WITHIN 1000'
	1500	91-97 SCHOOL STREET HYDRANTS AT 127 SCHOOL STREET OR 101 MAIN STREET, BOTH WITH IN 1000',
	1500	104-127 HYDRANTS AT 127 SCHOOL STREET OR 101 MAIN STREET, BOTH WITH IN 1000'
SEA LANE	1000	4-9 SEA LANE HYDRANT AT CORNER OF EDGEWOOD AND WILDWOOD AVE WITHIN 1000' LAY
SEAGRASS LANE	1000	6-10 SEAGRASS LANE HYDRANT AT EAST AVE AND OCEAN AVE and
	1000	HYDRANT AT 116 OCEAN AVE (KENNEBUNK RIVER CLUB) BOTH W/1000'
SEA VIEW AVENUE	750	6-23 SEA VIEW AVE HYDRANTS AT SEAVIEW AND WINDEMERE PLACE AND
	750	OCEAN AND WINDEMERE PLACE W/1000'
SERENITY WAY		DRY HYDRANT AT 7 ROCKMARSH LANE 900' TO START OF ROAD
	DH	250-500 gpm, 250 gpm 4 hours
SHERWOOD DRIVE	750	4-6 SHERWOOD DRIVE HYDRANTS AT 9 SHERWOOD AND 8 WOODLAWN BOTH WITHIN 1000'
SHORE FARM LANE	1500	6-37 SHORE FARM LANE HYDRANT AT WILDES DISTRICT AND LANDS END ROAD
		1500' LAY TO THE THREE WAY SPLIT AND 2000' MORE FEET TO END OF ROAD (3500' LAY TOTAL)
	DH	DRY HYDRANT AT ABOUT 3 SHORE FARM LANE 250-500 gpm, 250 gpm 2 hours
SINNOTT ROAD	1500	6-8 SINNOTT ROAD HYDRANT AT WALKERS LANE AND NORTH ST. W/1000'
SKIPPER JOES POINT ROAD	1500	4-35 SKIPPER JOES POINT ROAG HYDRANT AT 73 MARSHALS POINT RD
	1500	AND 19 SKIPPER JOES POINT ROAD BOTH W/1000'
	1500	36-41 SKIPPER JOES POINT ROAD HYDRANT AT 29 SKIPPER JOES WITH IN 1000'
SKYDANCE LANE		11-19 SKYDANCE LANE DRY HYDRANT AT 151 GOOSE ROCKS ROAD W/1500'
	DH	250-500 gpm, 250 gpm 4 hours
SKYLINE DRIVE	750	1-23 SKYLINE DRIVE HYDRANT AT 15 COMMUNITY HOUSE DRIVE W/1000'
SLACK TIDE ROAD	1500	15-27 SLACK TIDE ROAD HYDRANT AT 11 MULLS ROAD W/1300'
SONGBIRD DRIVE	1000	1-3 SONGBIRD DRIVE HYDRANT AT 9 BROOK SIDE DRIVE WITH IN 1000'
SOUTH MAIN STREET	1000	2-6 S. MAIN HYDRANT AT WIKDES DISTRICT ROAD AND SOUTH MAIN
		NEXT HYDRANT AT 6 SOUTH MAIN BOTH WITH IN 1000'
	1000	7-16 S. MAIN HYDRANT AT 6 SOUTH MAIN BOTH WITH IN 1000'
		NEXT AT 16 SOUTH MAIN STREET BOTH WITH IN 1000' LAY
	1000	19-29 S. MAIN HYDRANT AT 16 SOUTH MAIN NEXT AT 28 SOUTH MAIN
		STREET BOTH WITH IN 1000' LAY
	1000	36-58 S. MAIN HYDRANT AT 28 SOUTH MAIN NEXT AT 36 SOUTH MAIN
	STREET BOTH WITH IN 1000' LAY	
	1000	61-64 S. MAIN HYDRANT AT 58 SOUTH MAIN NEXT AT 64 SOUTH MAIN
		STREET BOTH WITH IN 1000' LAY
	1000	66-74 S. MAIN HYDRANT AT 64 SOUTH MAIN NEXT AT SOUTH MAIN

		STREET AND ARLINGTON AVE BOTH WITH IN 1000' LAY
SOUTH STREET	1500	3-10 SOUTH STREET HYDRANT SOUTH AND MAINE W/1000'
SPOUTING ROCK AVE		No addresses listed
SPRING STREET	1000	1-16 SPRING STREET HYDRANTS AT SPRING AND MAINE
	1500	AND CROSS AND SPRING BOTH WITH IN 1000'
SPRING VALLEY RD.	1000	3-7 SPRING VALLEY ROAD HYDRANT AT SOUTH MAIN AND STREET W/1000'
SPRUCE AVENUE		3-14 SPRUCE AVE DRY HYDRANT AT 178 GUINEA ROAD MAX LAY 1000'
	DH	250-500 gpm, 250 gpm 4 hours
SQUIER LANE	1500	7-23 SQUIER LANE HYDRANT AT ABOUT 12 SQUIER LANE W/1000'
STAGE ROAD	1500	5-11 STAGE ROAD HYDRANTS AT 11 AND 23 MILLS ROAD BOTH W/1000'
STAPLES LANE		DRY HYDRANT AT NEW BIDDEFORD AND MILLS ROAD W/1500'
	DH	250-500 gpm, 250 gpm 2 hours
STAR DUST LANE		PRIVATE ROAD DRY HDRANT AT 7 ROCKMARSH ROAD A 2000' LAY
	DH	250-500 gpm, 250 gpm 4 hours
STRIPER WAY	1500	HYDRANT AT 9 PIER ROAD
STONE HAVEN DRIVE	1000	1-4 STONE HAVEN ROAD HYDRANT AT PIER AND STONE HAVEN W/1000'
STONE ROAD		5-20 STONE ROAD DRY HYDRANT AT BEACHWOOD AND BATSON RIVER W/1000' (HUTCHINS SCHOOL BRIDGE) 24 STONE ROAD DRY HYDRANT AT STONE ROAD BRIDGE WITH IN 1000' SECOND DRY HYDRANT AT HUTCHINS SCHOOL BRIDGE WITHIN 1300' 59 STONE ROAD DRY HYDRANT AT STONE ROAD BRIDGE WITH IN 1700' SECOND DRY HYDRANT AT HUTCHINS SCHOOL BRIDGE WITHIN 3300' 71-73 STONE ROAD DRY HYDRANT AT STONE ROAD BRIDGE WITH IN 2300'SECOND DRY HYDRANT AT HUTCHINS SCHOOL BRIDGE W/3600' 75-79 STONE ROAD DRY HYDRANT AT 286 GOOSE ROCKS ROAD 2000'
	DH	250-500 gpm, 250 gpm 4 hours
		81 STONE ROAD DRY HYDRANT AT 286 GOOSE ROCKS ROAD 2800' 91-99 STONE ROAD DRY HYDRANT AT 286 GOOSE ROCKS ROAD W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
STONEWOOD LANE		1-12 STONE WOOD DRIVE DRY HYDRANT AT 20 NORTH WOOD DRIVE, WITHIN 1000' LAY
	DH	250-500 gpm, 250 gpm 2 hours
SUMAC LANE	1000	3-6 SUMAC LANE HYDRANT AT START OF ROAD W/1000'
SUMMER BREEZE LANE	750	4-8 SUMMER BREEZE LANE HYDRANT AT 15 COMMUNITY HOUSE ROAD, /1000' LAY
SUMMIT AVENUE	750	3-12 SUMMIT AVE HYDRANT AT SUMMIT AND CENTRAL AVE, SUMMIT & ATLANTIC BOTH W/1000'
	750	14-26 SUMMIT AVE HYDRANT AT ATLATIC AND SUMMIT, OCEAN & SUMMIT BOTH W/1000'
SUNSET LANE	1500	3-9 SUNSET LANE HYDRANT AT 491 KINGS HIGHWAY OPPOSITE SUNSET LANE MAX LAY 1000'
TALL PINE DRIVE		11 TALL PINE DRIVE DRY HYDRANT AT 33 OLD CAPE ROAD WITHIN 2000' LAY DRY HYDRANT AT 64 BEACHWOOD AVE W/2000'.
	DH	250-500 gpm, 250 gpm 2 hours
TANGLEWOOD ROAD		15-20 TANGLEWOOD ROAD DRY HYDRANT AT 145 ARUNDEL ROAD W/2000'
	DH	250-500 gpm, 250 gpm 2 hours
TEMPLE STRET	1500	1-8 TEMPLE STREET HYDRANT AT NORTH AND MAINE STREETS
	1500	CHURCH STREET BOTH W/1000'
THE LONG AND WINDING ROAD		10 THE LONG AND WINDING ROAD DRY HYDRANT 330 FEET IN FROM ARUNDEL ROAD ON THE RIGHT W/1000' 27 THE LONG AND WINDING ROAD DRY HYDRANT 330 FEET IN FROM ARUNDEL ROAD ON THE RIGHT W/1600' 34-47 THE LONG AND WINDING ROAD DRY HYDRANT 330 FEET IN FROM ARUNDEL ROAD ON THE RIGHT W/2500'

	DH	250-500 gpm, 250 gpm 2 hours
THUNDER HILL LANE		DRY HYDRANT AT 286 GOOSE ROCKS ROAD 2800'
	DH	250-500 gpm, 250 gpm 2 hours
TIDAL SHORE DRIVE		8-17 TIDAL SHORE DRIVE DRY HYDRANT AT MILLS ROAD AND TYLER BROOK (SALT WATER) WITHIN 1000' 40-50 TIDAL SHORE DRIVE DRY HYDRANT AT MILLS ROAD AND TYLER BROOK (SALT WATER) WITHIN 1400' ROAD MAKES A LOOP 40-50 CAN BE ACCESSED ON THE UPPER PART OF THE LOOP
	DH	250-500 gpm, 250 gpm 4 hours
TIMBER LEDGE LN.		5-7 TIMBER LEDGE ROAD LAY HYDRANT AT NEHOC LANE AND TURBATS CREEK ROAD, W/1000'
	750	
TIMBER WAY	1000	HYDRANT AT 46 TIMBER WAY
TOUCHSTONE DRIVE	750	2-15 TOUCHSTONE DRIVE HYDRANT AT 15 TOUCHSTONE
	1000	AND 16 S. MAIN STREET BOTH W/1000'
TOWNE STREET	1500	3-15 TOWNE STREET HYDRANT AT 9 SCHOOL STREET MAX LAY OF 1000'
TRADEWINDS LANE		DRY HYDRANT AT 305 GOOSE ROCKS ROAD IS WITHIN A 1500' LAY TO START OF ROAD
	DH	250-500 gpm, 250 gpm 2 hours
TURBATS CREEK RD.	1000	5-22 TURBATS CREEK ROAD HYDRANT AT WILDWOOD FIRE STATION W/1000'
	750	23-36 TURBATS CREEK ROAD HYDRANT AT 22 TURBATS CREEK RD
	750	39-53 TURBATS CREEK ROAD HYDRANT AT 36 TURBATS CREEK RD W/1000'
	750	55-74 TURBATS CREEK ROAD HYDRANT AT 56 TURBATS CREEK RD W/1000'
	750	74-92 TURBATS CREEK ROAD HYDRANT AT 74 TURBATS CREEK RD W/1000'
TYLER BROOK ROAD		8 TYLER BROOK ROAD DRY HYDRANT AT MILLS ROAD AND TYLER BROOK WITHIN 1000' LAY
	DH	250-500 gpm, 250 gpm 4 hours
UNION STREET	1500	3-8 UNION STREET HYDRANTS AT MAINE IN FRONT OF LIBRARY AND UNION AND OCEAN AVE.
VAUGHN ISLAND BLVD		1-16 VAUGHN ISLAND BLVD DRY HYDRANT AT 3 SHORE FARM RD
	DH	250-500 gpm, 250 gpm 2 hours
	1500	HYDRANT AT LANDS END ROAD AND PADDY CREEK HILL ROAD W/2500'
WALDHEIM LANE		DRY HYDRANT AT 372 MILLS ROAD A 1000' LAY TO START OF THE ROAD
	DH	250-500 gpm, 250 gpm 2 hours
WAKEFIELD PASTURE	1000	1-18 WAKEFIELD PASTURE ROAD HYDRANT AT 2 WAKEFIELD PASTURE ROAD WITH IN 1000'
WALKERS LANE	1500	2-28 WALKERS LANE HYDRANT AT WALKERS LANE AND NORTH STREET WITH IN 1400' LAY
WARD ROAD	1500	6-20 WARD ROAD HYDRANTS AT 150 MAIN STREET AND 7 WARD ROAD W/1000'
	1000	21-26 WARD ROAD HYDRANTS AT 15 LANGSFORD ROAD AND 7 WARD ROAD W/1000'
WASHBURN DRIVE	750	1-16 WASHBURN DRIVE HYDRANT AT OCEAN AND WASHBURN DRIVE W/1000'
	750	7-27 WASHBURN DRIVE HYDRANT AT 17 WASHBURN DRIVE W/1000'
	750	27-38 WASHBURN DRIVE HYDRANT AT 38 WASHBURN DRIVE W/1000'
WASHINGTON COURT	1500	1-11 WASHINGTON COURT HYDRANT AT 70 SCHOOL STREET OPPOSITE WASHINGTON COURT W/1000'
WATERSIDE LANE	1500	HYDRANT AT 491 KINGS HIGHWAY W/1000'
WESMORE LANE	1500	1-7 WESMORE LANE HYDRANT AT 22 NORTH STREET AND 34 NORTH STREET BOTH WITH IN 1000'
WEST STREET	1500	3-11 WEST STREET HYDRANT IS AT 16 NORTH STREET w/1000'
	1500	1 OAK STREET w/1000'
WESTVALE ROAD	1500	1-5 WESTVALE ROAD HYDRANT 133 MAIN STREET W/1000'
WHARF LANE	1500	3-7 WHARF LANE HYDRANTS AT 33 AND 48 OCEAN AVE BOTH W/1000'
WHITE CREEK LANE	1500	HIGHEST # IS #24. HYDRANT AT 98 WILDES DISTRICT ROAD
WHITTEMORE LANE		2-14 WHITTEMORE LANE HYDRANT AT 491 KINGS HIGHWAY OPPOSITE SUNSET LANE
	1500	WITH IN A 1000' LAY
WHITTEN HILLS RD.		2-9 WHITTEN HILL ROAD DRY HYDRANT AT 305 GOOSE ROCKS ROAD W/1000'

		22 WHITTEN HILL ROAD DRY HYDRANT AT 56 WHITTEN HILL RD W/1700' 23 WHITTEN HILL ROAD DRY HYDRANT AT 56 WHITTEN HILL RD W/1600' 30-36 WHITTEN HILL ROAD DRY HYDRANT AT 56 WHITTEN HILL RDW/1300' 38-70 WHITTEN HILL ROAD DRY HYDRANT AT 56 WHITTEN HILL RD W/1000' 81-87 WHITTEN HILL ROAD DRY HYDRANT AT 56 WHITTEN HILL RD W/1700' 89-128 WHITTEN HILL ROAD DRY HYDRANT AT 109 WHITTEN HILL RD W/1000' 129 WHITTEN HILL ROAD DRY HYDRANT AT COLE BENSON ROAD & GUINEA ROAD W/1200' 135-139 WHITTEN HILL ROAD DRY HYDRANT AT COLE BENSON ROAD & GUINEA W/1000'
	DH	250-500 gpm, 250 gpm 2 hours
WILD HORSE RUN		15 WILD HORSE RUN DRY HYDRANT AT MILLS RD & TYLER BROOK /1000'
	DH	250-500 gpm, 250 gpm 4 hours
WILDES DISTRICT ROAD	1500	1-20 WILDES DISTRICT ROAD HYDRANTS AT WILDES DISTRICT ROAD AND MAINE STREET AND 20 WILDES DISTRICT ROAD BOTH W/1000'
	1500	22-44 WILDES DISTRICT ROAD HYDRANTS AT 20 WILDES DISTRICT ROAD AND 44 WILDES DISTRICT ROAD BOTH WITHIN 1000'
	1500	46-68 WILDES DISTRICT ROAD HYDRANTS AT 44 AND 58 WILDES DISTRICT ROAD BOTH WITH IN 1000'
	1500	70-88 WILDES DISTRICT ROAD HYDRANTS AT 68 AND 88 WILDES DISTRICT ROAD BOTH WITHIN 1000' LAY
	1500	89-114 WILDES DISTRICT ROAD HYDRANTS AT 88 AND 114 WILDES DISTRICT ROAD BOTH WITH IN 1000' LAY
	1500	116-134 WILDES DISTRICT ROAD HYDRANTS AT 114 WILDES DISTRICT WITH IN 1000'
	1500	136-164 WILDES DISTRICT ROAD HYDRANTS AT 144 WILDES DISTRICT WITH IN 1000'
	1500	164-184 WILDES DISTRICT ROAD HYDRANTS AT 163 WILDES DISTRICT ROAD AND 150 MAIN STREET W/1000'
WILDWOOD AVENUE	1500	2-7 WILDWOOD AVE HYDRANT AT 242 KINGS HIGHWAYYY CORNER OF BARTLETT AVE
	1500	8-20 WILDWOOD AVE HYDRANT AT BARTLETT AVE AND KINGS HIGHWAY W/1000'
	1000	22-30 WILDWOOD AVE HYDRANT AT EDGEWOOD AND WILDWOOD AVE W/1000'
	1000	31-47 WILDWOOD AVE HYDRANT AT PROCTOR AVE AND WILDWOOD AVE WITHIN A 1000'
WILLEY ROAD		10-42 WILLEY ROAD DRY HYDRANT AT 22 WILLEY ROAD W/1000' 46-61 WILLEY ROAD DRY HYDRANT AT REAR 53 WILLEY ROAD W/1000'
	DH	250-500 gpm, 250 gpm 4 hours
WINDEMERE PLACE	750	HYDRANTS AT OCEAN AND WINDEMERE PLACE AND WINDEMERE PLACE AND SEAVIEW AVE
WINSLOW LANE	1500	7-11 WINSLOW LANE HYDRANTS AT HIGH POINT AND SADDLE WAY W/1000'
WINTER HARBOR RD		2-29 WINTER HARBOR RD 35 DRY HYDRANT AT 12 WINTER HARBOR ROAD W/1000' 45 DRY HYDRANT AT 12 WINTER HARBOR ROAD W/1400' 49-52 DRY HYDRANT AT NEW BIDDEFORD AND MILLS ROAD w/1500' 53-66 DRY HYDRANT AT NEW BIDDEFORD AND MILLS ROAD w/1000'
	DH	250-500 gpm, 250 gpm 2 hours
WOLFF FARM LANE		DRY HYDRANT AT 372 MILLS ROAD A 300' LAY TO THE START OF THE
	DH	250-500 gpm, 250 gpm 2 hours
WOOD ROAD	750	2-10 WOOD ROAD HYDRANT AT 59 LANGS FORD ROAD W/1000'
WOODLAWN AVENUE	1000	4-20 WOODLAWN DRIVE HYDRANT AT WOODLAWN AND SHERWOOD W/1000'
	1500	HYDRANT AT WILDES DISTRICT ROAD AND WOODLAWN